

## DECLARATION OF PERFORMANCE

No. DOP0003-07-06-2013

1. Unique identification code of the product-type:

**CLKS 400 series polypropylene channel**

2. Type, batch of serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

**CLKS 422/64    CLKS 422/96    CLKS 422/56/W**

3. Intended use or uses of the construction product, in accordance with the applicable harmonised technical specification, as foreseen by the manufacturer:

**Drainage channel Type M for the collection and conveyance of surface water from areas used by pedestrians and pedal cyclists**

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**Clark-Drain Limited  
Station Road  
Yaxley  
Peterborough  
PE7 3EQ ENGLAND**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

**N/A**

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

**System 3**

7. In case of the declaration of performance concerning a construction product covered by a harmonised standard:

**EN1433:2002**

**British Standards Institute UK No. 0086 performed initial type testing in accordance with Annex ZA.1 of EN1433:2002 and confirmed by way of test report No. 2381/7919215 the performance as declared in point 8**

8. Declared performance

Essential characteristics	Performance	Harmonised technical specification												
<b>4. Classification</b> Designated Class A15	<b>Pass (see 7.15)</b>	<b>EN 1433:2002</b>												
<b>5. Places Installation for Drainage Channels</b> Intended for installation in Group 1 areas	<b>Pass</b>													
<b>7.10 Dimension of inlet openings, 7.10.1 Straight Slots, 7.10.1.1 Classes A15 to B125:</b>  <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;"></td> <td style="text-align: center;"><b>Specified</b></td> <td style="width: 50%;"></td> </tr> <tr> <td>Slot width (mm)</td> <td style="text-align: center;">5-18</td> <td style="text-align: center;"><b>Actual</b></td> </tr> <tr> <td>Slot length (mm)</td> <td style="text-align: center;">-</td> <td style="text-align: center;">7.4-7.5 (Pass)</td> </tr> <tr> <td></td> <td></td> <td style="text-align: center;">23.2-23.4 (Pass)</td> </tr> </table>			<b>Specified</b>		Slot width (mm)	5-18	<b>Actual</b>	Slot length (mm)	-	7.4-7.5 (Pass)			23.2-23.4 (Pass)	
	<b>Specified</b>													
Slot width (mm)	5-18		<b>Actual</b>											
Slot length (mm)	-	7.4-7.5 (Pass)												
		23.2-23.4 (Pass)												
<b>7.15 Strength Testing, 7.15.2 Gratings &amp; Covers:</b> Tested in accordance with clause 9.1.4.1 the covers of three units withstood loads of 9kN without failure	<b>Pass</b>													
<b>7.16 Permanent Set:</b> Three units tested in accordance with clause 9.1.4.2.1 using a load of 6kN  <table style="width: 100%; border: none;"> <tr> <td style="width: 50%;"></td> <td style="text-align: center;"><b>Specified</b></td> <td style="width: 50%;"></td> </tr> <tr> <td>Permanent set (mm)</td> <td style="text-align: center;">1.95max</td> <td style="text-align: center;"><b>Actual</b></td> </tr> <tr> <td></td> <td></td> <td style="text-align: center;">0.35-0.50 (Pass)</td> </tr> </table>		<b>Specified</b>		Permanent set (mm)	1.95max	<b>Actual</b>			0.35-0.50 (Pass)					
	<b>Specified</b>													
Permanent set (mm)	1.95max	<b>Actual</b>												
		0.35-0.50 (Pass)												

9. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 8. This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.

Signed for and on behalf of the manufacturer by:

Jeremy Nesbitt, Technical Manager

Yaxley, Peterborough

7<sup>th</sup> June 2013